

An Overview of the Greek Islands' Autonomous Electrical Systems: Proposals for a Sustainable Energy Future

Nikolas M. Katsoulakos

Metsovion Interdisciplinary Research Center, National Technical University of Athens, Athens, Greece

Email: katsoulakos@metal.ntua.gr

How to cite this paper: Katsoulakos, N.M. (2019) An Overview of the Greek Islands' Autonomous Electrical Systems: Proposals for a Sustainable Energy Future. *Smart Grid and Renewable Energy*, 10, 55-82. <https://doi.org/10.4236/sgre.2019.104005>

Received: March 7, 2019

Accepted: April 14, 2019

Published: April 17, 2019

Copyright © 2019 by author(s) and Scientific Research Publishing Inc. This work is licensed under the Creative Commons Attribution International License (CC BY 4.0).

<http://creativecommons.org/licenses/by/4.0/>



Open Access

Abstract

Among the Greek islands, 61 are based—currently—on autonomous electrical systems for covering the electrical energy demand and are characterized as Non-Interconnected Islands (NII). The average electricity production cost in the NII is 2.5 times higher than in areas with access to the main, interconnected electricity grid (IEG) of Greece. In this paper, an analytic overview of the autonomous electricity systems of Greek islands is provided, focusing on electricity consumption and production, as well as on the relative costs. For investigating possibilities for improving the situation, especially in small, remote islands, simulations for the energy system of Astypalea are conducted. It is proved that further use of renewables in combination with energy storage can lower the current, high energy costs. Expansion of the IEG is not economically viable for islands which are far away from the mainland and their peak loads are less than 10 MW.

Keywords

Greek Islands, Autonomous Energy Systems, High Energy Costs, Energy Optimization, Astypalea

1. Introduction

The great number of islands and the extensive mountain ranges are distinctive features of Greece's natural geography. The Constitutional Law of the country includes a special reference (Article 101, paragraph 4) to island and mountain territories: "The common Legislator and the Administration, when setting regulations, are obliged to consider the particular circumstances of island and mountain areas, catering for the development of these areas" [1]. The author has

been systematically involved in research regarding the particularities of energy planning in mountainous areas [2] [3] [4]. Considering Greece's geography, as well as the necessity for setting up specialized strategies both for mountains and islands in the country, the present work is aiming at identifying energy policies for the Greek islands.

As regards the islands some more specific facts, following the data provided by the Hellenic Statistical Authority (HSA), are the following [5]:

- The total area of Greek islands represents about 15% of the total area of the country, not including Euboea.
- The total number of islands exceeds 2500, but only about 165 of them are inhabited.
- The total population of Greek islands represents about 12% of the total population of the country (1,339,166 inhabitants, not including Euboea).
- Crete, Rhodes, Corfu and Lesvos gather almost 70% of the islands' population; more than 40 islands have populations less than 1000 persons.
- Greek islands are particularly important for the Greek economy; Crete, Rhodes, Corfu, Mykonos, Santorini (Thira), Paros are some of the most popular touristic destinations, at global level.

Many of the islands are far away from the mainland. So, they need to be electrified by autonomous electrical systems and grids. These islands are defined as Non-Interconnected Islands (NII) by the Greek legislation and the Regulatory Authority of Energy (RAE). The NII, according to the Hellenic Electricity Distribution Network Operator (HEDNO), have four main characteristics [6]:

- 1) They differ significantly in area and population and, in many cases, they are not easily accessible, especially from the sea.
- 2) They have abundant renewable energy potential, particularly wind and solar energy potential.
- 3) They cannot exchange electricity with other electrical systems, and this affects the reliability and security of energy supply.
- 4) Since they are not interconnected with electrical systems of high inertia, there are problems regarding stability of voltage and frequency, particularly in cases of high penetration rates of intermittent renewable energy sources (RES).

HDNO, as operator of the NII systems electrical grids, has set some strategic aims for improving the current situation in these off-grid electrical systems. Until 2020, it is planned to: 1) complete the basic infrastructure of HDNO in the NII, 2) to enhance the infrastructure of NII regarding energy monitoring and metering, 3) upgrade the energy market in the NII and, 4) complete pilot projects of energy autonomous islands, which will set up the basis for the energy future of NII [6]. Basic part of these strategic aims is the interconnection of the NII to the electrical grid of mainland Greece, wherever this is possible.

The paper provides a broad view of the electrical systems of the NII and their characteristics and investigates possibilities for upgrading autonomous electrical systems in a sustainable way. Although the literature regarding energy in the Greek islands is not poor, e.g. [7] [8] [9], an overall examination of the energy

landscape in the NII is missing from the bibliography. Therefore, the present paper tries to provide this overview by combining data related to the NII found retained by different bodies, like HDNO, RAE, HSA etc. Some further useful conclusions are reached by correlations between parameters of the energy data of the NII. Then, the island of Astypalea, which is a representative example of small-scale autonomous electrical system operation, is used as a case study, in order to investigate solutions that will improve the future perspectives of NII in the energy sector. To do so, optimization of Astypalea energy system is conducted and various solutions are tested. Hence, the paper is an integrated approach to the NII electrical systems, since it combines analysis of secondary data with energy planning optimization, in order to draw policy conclusions.

The data and methodology used for composing the present paper are presented in Section 2. The characteristics of the NII electrical systems, the statistical analysis of the corresponding data and the findings from energy optimization in the island of Astypalea are included in Section 3. In Section 4 estimations regarding the interrelation of the study's results with energy policy are mentioned. Finally, in Section 5 the most important points of the paper are summarized, and conclusions are extracted.

2. Materials and Methods

In order to gain a broad view of the Greek NII electrical systems, firstly, data were collected. The necessary data were retrieved, mainly, from HEDNO, which has given public access to the following information for the NII:

- Electricity production, at monthly basis, from thermal stations (years 2014 to 2017).
- Electricity production, at monthly basis, from renewable energy plants (years 2014 to 2017).
- Variable cost of electricity production, at monthly basis (years 2014 to 2017).
- Total cost of electricity production, at monthly basis (years 2014 to 2017).

Data related to the installed power capacity of the NII energy units were collected both from HEDNO and RAE. The HSA was the main source for demographic and socioeconomic data for the NII. The Operator of the Electricity Market (OEM) was the source of data regarding: 1) electricity consumption in the whole of the country, and 2) marginal price of electricity production in the Interconnected Grid.

The statistical analysis of the NII electrical systems characteristics was conducted by using Microsoft Excel (for simple statistical analysis and graphs' composition) and SPSS/Statistical Package for the Social Sciences (for correlation and regression analysis).

As far as the optimization of Astypalea electrical system is concerned, hourly load data were provided by HDNO, for the years 2014 and 2015. The optimization was realized by using HOMER software (version PRO x64). HOMER's goal is to find the least cost combination of equipment for consistently meeting the

electric load [10]. Main aim of the energy optimization in Astypalea was to explore ways to decrease the current high electricity production costs, with parallel increase in the share of renewables. To this direction, the objectives of the procedure were:

- Testing how various combinations of energy sources and energy storage systems can lower the energy cost and footprint of the local energy system.
- Checking the feasibility of grid expansion from the mainland to the island of Astypalea.
- Conducting sensitivity analysis with respect to various important parameters of the energy system.

In order to validate the reliability of the optimization software and the general assumption that were made, the current main elements (diesel generators, photovoltaic array, diesel oil price etc.) of Astypalea's electrical systems were entered into HOMER and the optimization results led to a solution very close to the actual situation of the local energy system.

3. Results and Discussion

3.1. Energy Production Units in the Non-Interconnected Islands

The energy production cluster of NII is composed by 32 autonomous electrical systems, which provide electricity to 61 islands, which are shown in **Table 1**, as well as their permanent population, according to the census of the Hellenic Statistical Authority [11]. The production of electricity is based on thermal stations, which operate with heavy oil (mazut) or light oil (diesel). The installed capacity of the NII thermal stations is presented in **Table 2**. In total, during 2017, the installed capacity was 1808.35 MW [12]. In addition, renewable energy plants are operating in many of the NII, whose capacity is also shown in **Table 2**. The total capacity of RES station in the NII was 459.59 MW in the first four months of 2018. Regarding shares in energy consumption, 81.5% of it is covered by thermal stations and 18.5% by RES stations. The RES share is distributed as follows:

- 60.7% wind power.
- 34.3% solar power (photovoltaic stations).
- 4.7% solar power (rooftop photovoltaics and net-metering).
- 0.3% from other RES (this is the estimated contribution to RES energy from a small hydro-station with nominal capacity of 0.3 MW and a small biogas unit with nominal capacity 0.5 MW, which are operating in Crete).

It is noted that an important characteristic of the NII energy systems is the use of generators (mainly diesel powered) for covering extra, seasonal needs in electricity. The generators are as a rule rented by the energy producers and transported to the islands. This, of course, causes increases in energy production costs and will be further analyzed in Section 3.3. The management of the energy market in the NII is made by the Hellenic Electricity Distribution Network Operator S.A. (HEDNO). A general categorization of the 32 autonomous electrical systems of the NII is the following:

- 19 electrical systems are small-sized, with peak loads less than 10 MW.
- 10 electrical systems are medium-sized, with peak loads between 10 and 100 MW.
- 3 electrical systems are big-sized, with peak loads more than 100 MW (the ones of Crete, Rhodes and Kos-Kalymnos).

Table 1. Energy systems of NII and population served by them [11] [13].

No.	Autonomous system	Served islands	Served population	No.	Autonomous system	Served islands	Served population		
1	Agios Efstratios	Agios Efstratios	270	19	Megisti	Megisti	492		
2	Agathonissi	Agathonissi	185	20	Milos	Milos	5887		
3	Amorgos	Amorgos	1973			Kimolos			
4	Anafi	Anafi	271	21	Mykonos	Mykonos	10,134		
5	Antikythira	Antikythira	68			Delos			
6	Arki	Arki	49			22		Othoni	Rinia
		Marathi							
7	Astypalea	Astypalea	1334	23	Paros	Paros	36,725		
8	Gavdos	Gavdos	152			Naxos			
9	Donoussa	Donoussa	167			Antiparos			
10	Erikoussa	Erikoussa	496			Koufonissi			
11	Thira	Thira	15,550	24	Patmos	Shinoussa	115,968		
		Thirasia				Iraklia			
12	Ikaria	Ikaria	8423	25	Rhodes	Sikinos	34,436		
13	Karpathos	Karpathos	7310			26		Samos	Folegandros
		Kassos							Ios
14	Crete	Crete	622,913	27	Serifos	Patmos	3047		
15	Kythnos	Kythnos	1456	28	Sifnos	Rhodes	52,674		
		Kalymnos				Chalki			
		Lipsi				Samos			
		Leros				Fourni			
		Telendos				Thymena			
16	Kos-Kalymnos	Kos	59,477	29	Skyros	Serifos	1420		
		Pserimos	86,436	30	Symi	Sifnos	2625		
		Giali		31	Syros	Skyros	2994		
		Nisiroi		32	Chios	Symi	2590		
		Tilos		Syros	21,507				
Lesvos	Chios								
17	Lesvos	Megalonisi	86,436	32	Chios	Inousses	52,674		
18	Lemnos	Lemnos	16,992			Psara			

Table 2. Installed capacity of thermal and RES stations in the NII-year 2017 [12].

NII System	Capacity of thermal stations (MW)	Capacity of RES stations (MW)	NII System	Capacity of thermal stations (MW)	Capacity of RES stations (MW)
Agios Efstratios	0.84	0.02	Lesvos	94.88	22.79
Agathonissi	0.64	0.00	Lemnos	23.60	4.93
Amorgos	6.20	0.29	Megisti	1.73	0.00
Anafi	1.15	0.00	Milos	22.98	3.27
Antikyhtira	0.41	0.00	Mykonos	67.49	2.24
Arkioi	0.41	0.00	Othoni	0.66	0.66
Astypalea	3.83	0.32	Paros	93.72	17.07
Gavdos	0.43	0.00	Patmos	8.93	1.35
Dosnoussa	0.99	0.00	Rhodes	232.93	66.71
Erikoussa	0.77	0.00	Samos	49.63	12.75
Thira	75.09	0.25	Serifos	6.69	0.10
Ikaria	15.89	1.39	Sifnos	11.48	0.20
Karpathos	16.50	2.39	Skyros	8.45	0.32
Crete	796.82	279.38	Symi	8.60	0.19
Kythnos	5.92	0.91	Syros	39.25	3.83
Kos-Kalymnos	133.66	23.98	Chios	77.78	14.25

3.2. Electrical Energy Consumption and Production in the NII

According to the data published by HDNO for the years 2014-2017 (48 months, in total), the electrical energy consumption and production of all the electrical systems of the NII can be summarized as follows:

- Average, annual consumption: 5,672,339 MWh (standard deviation equal to 176,854.15 MWh or 3.12%).
- Average, annual electricity production from thermal stations: 4,643,288 MWh (standard deviation equal to 144,617.78 MWh or 3.11%).
- Average, annual electricity production from RES: 1,029,051 MWh (standard deviation equal to 60,363.98 MWh or 5.87%).

The electricity consumption of the NII corresponds to about 10% of the total electricity consumption of Greece [14].

The total, average electrical energy consumption in the NII is presented in **Figure 1**, as well as the electricity consumption of the three biggest autonomous systems (Crete, Rhodes, Kos-Kalymnos). It is notable that these three systems represent, in average, 73% of the total energy consumption of all 31 autonomous NII systems.

The electricity consumption is maximized during August (692,969 MWh) and minimized during November (356,109 MWh). The maximum monthly consumption is 95% higher than the minimum one. This illustrates one of the most distinctive characteristics among the electrical systems of the NII. The population in many islands increases during the summer due to tourism. So, great

fluctuations are observed in the energy consumption. In the case of Mykonos, an island famous worldwide for summer tourism, in August the electricity consumption is 362% higher than in November (Figure 2). Because of the population increase during the summer, in many cases, the installed capacity of power stations is much greater than the capacity needed for the permanent inhabitants of the islands. This is reflected in the installed capacity per capita; in the NII the installed electricity capacity per capita is 21% higher than in mainland Greece, served by the interconnected electricity network [14]. In the case of Mykonos, the installed capacity per capita is 390% higher than the average in mainland Greece. The lowest fluctuation in electricity consumption is noticed in the case of Lesvos (55%), whose economy is not exclusively based on tourism. This value of fluctuation in electricity consumption is similar to the one of the IEG [15]. In Table S1 of the Appendix, the average electricity production from thermal stations and RES per month for the period 2014-2017, in each of the NII systems is presented.

In Table 3 the average production from thermal and power stations per month in each NII is presented. The great differences in electricity consumption between the several NII is clearly shown in this Table. The thermal station of the autonomous system of Antikythira produces, in average, 21.54 MWh, whereas the mean production of Crete's thermal stations exceeds 190,000 MWh. Such great differences in energy demand imply that there is no a single way for managing and improving the energy systems in the NII. On the contrary, specialized strategies, adopted to local differentiations should be developed.

Table 3. Average, monthly electrical energy consumption from thermal and RES station in the NII.

NII System	Thermal stations production (MWh)	RES stations production (MWh)	NII System	Thermal stations production (MWh)	RES stations production (MWh)
Agios Efstratios	92.13	0.00	Lesvos	20,597.55	3986.49
Agathonissi	58.84	0.00	Lemnos	4342.31	633.13
Amorgos	793.72	40.83	Megisti	278.55	0.00
Anafi	105.33	0.00	Milos	3636.21	664.94
Antikyhtira	21.54	0.00	Mykonos	10,777.76	381.94
Arkioi	29.38	0.00	Othoni	52.34	0.00
Astypalea	521.76	49.12	Paros	14,660.81	3346.14
Gavdos	40.33	0.00	Patmos	1278.44	198.54
Dosnoussa	70.52	0.00	Rhodes	56,264.58	10,647.98
Erikoussa	66.69	0.00	Samos	9178.84	2329.30
Thira	13,167.48	84.98	Serifos	753.72	18.03
Ikaria	2066.08	260.04	Sifnos	1548.54	49.18
Karpathos	2743.18	381.94	Skyros	1271.19	41.72
Crete	191,659.30	55,655.12	Symi	1190.19	22.65
Kythnos	761.76	32.53	Syros	7354.03	611.73
Kos-Kalymnos	26,699.95	3980.96	Chios	14,857.64	2336.94




Figure 1. Electrical energy consumption in the NII energy systems during the period 2014-2017.




Figure 2. Average monthly electrical energy consumption in the energy system of Mykonos during the period 2014-2017.

3.3. Energy Costs in the NII Electrical Systems

Maybe, the most distinctive feature of the autonomous energy systems of the Greek islands is the particularly increased cost of energy production. Besides, this is the reason that causes discussion about the necessity of changing the current situation in the islands. The great energy production cost is attributed, mainly, to two factors: 1) the thermal stations operating as base-load units use oil as fuel that is expensive, 2) the great fluctuations in energy demand that make necessary either the existence of particularly high installed capacity or the transfer of generators, in order to cover peaks of energy demand.

The high energy costs of the NII are covered by a special levy that is charged

to all electricity consumers, called “Services for common utilities” (SCU). SCU, according to the Law 4067/2012, are intended to cover: 1) the high energy costs of NII, 2) the very low electricity charges for families with four or more children, and 3) the low electricity charges of the so called Special Social Tariff that is a special electricity tariff for households with low income. The rates of SCU are the following for domestic electricity consumers [16]:

- 6.99€/MWh—consumption up to 1600 kWh/4 months.
- 15.70€/MWh—consumption 1601 to 2000 kWh/4 months.
- 39.87€/MWh—consumption 2001 to 3000 kWh/4 months.
- 44.88€/MWh—consumption over 3001 kWh/4 months.

The energy production cost presents differentiations among the NII; this is something that was expected because of the great differences between the energy consumption of the various energy systems. The weighted average of the variable cost all the NII electrical systems was 130.519€/MWh, between 2014 and 2017. The greatest cost is observed in the system of Antikythira (average variable cost 383.863€/MWh), which has the smallest electricity demand and it serves the smallest population among the NII. This autonomous system does not include any RES. The system with the lowest cost is the one of Chios (92.434€/MWh), which is a medium-sized system, with a share of renewables (15.7%), close to the average of the NII. In **Figure 3**, the variable cost in the NII is illustrated in descending order. The average marginal price of the interconnected electricity grid of Greece (AMPIG) is also included in **Figure 4**, to gain a comparative perspective. In the period 2014-2017 the average marginal cost was 51.338€/MWh [15]. The energy production in the system of Chios, with the lowest cost among the NII, is 80% more expensive than in the interconnected system. The weighted average marginal cost of the NII is 2.5 times higher than the AMPIG, and the variable cost of the Antikythira system is 7.5 higher than the AMCIS. These findings are indicative of the great economic burden of electricity in the NII and support the necessity of changing the current situation. The difference between the average variable cost in the NII and the AMPIG was 79.181€/MWh, as shown in **Figure 4**.

In the previous paragraph the term “variable cost” was used to refer to the energy production cost in the NII. According to the official definition, the variable cost of electricity in the NII, in €/MWh, is given by Equation (1) [17]:

$$MMK_{m,s} = \frac{KK_{m,s}}{Q_{\Sigma M,m,s}} + K\Lambda_{m,s} + \frac{KP_{m,s}}{Q_{\Sigma M,m,s}} \quad (1)$$

where:

- $KK_{m,s}$: Cost of fuel for electricity production, including the excise duty in €.
- $Q_{\Sigma M,m,s}$: The sum of net energy produced and supplied to the grid from all thermal stations of each autonomous system (s) per month (m) in MWh.
- $K\Lambda_{m,s}$: The additional variable operational cost of thermal stations in €/MWh.
- $KP_{m,s}$: The cost of greenhouse gas emissions in €/MWh.

The cost of fuel is determined by Equation (2) [17]:




Figure 3. Average variable electrical energy production cost in the NII, in the period 2014-2017 and average marginal price of the interconnected electricity grid during the same time-period.




Figure 4. Weighted, average variable cost of electricity production in the NII for the years 2014-2017.

$$KK_{m,s} = \Pi_{mazut_{m,s}} \cdot MK_{mazut_{m,s}} + \Pi_{diesel_{m,s}} \cdot MK_{diesel_{m,s}} \quad (2)$$

where:

- $\Pi_{mazut_{m,s}}$, $\Pi_{diesel_{m,s}}$: The quantities of mazut in tn and diesel in klit which are expected to be consumed in the electric system (s) in the month (m).
- $MK_{mazut_{m,s}}$, $MK_{diesel_{m,s}}$: The unit costs of mazut in €/tn and diesel in €/klit.

The variable cost is representative of the actual electricity production costs. The main factor that affects it is the fuel cost. The cost of greenhouse gas emissions is, for the time being, rather low. The relative data are not publicly accessi-

ble for every year. Indicatively, for the year 2013, the cost of greenhouse gas emissions is known represented less than 4% of the variable energy cost of the NII. According to the available data, between 2012 and 2015, the Public Power Corporation (PPC)—which is for the time being the only energy producer in the NII—spent nearly 2.5 billion euros for purchasing mazut and diesel oil for the thermal stations of NII. The relevant data are gathered in **Table 4**. Hence, **Figure 4**, which illustrates the weighted average variable energy cost in the NII, reflects the course of fuel prices.

According to the Regulation of NII [19], the conventional power stations receive revenues for:

- The energy they provide to the grids, based on the variable cost of electricity production and the starting cost of the power stations.
- The availability of electrical capacity (also known as cold power reserve).
- The provision of auxiliary services.

However, for the time being, the transitional provisions of the NII Regulation are being applied, since there are still pending problems for completing the reformation of the energy market of the NII. According to these transitional provisions, the energy producers that provide energy to the NII are compensated for the total energy production cost, which is defined by Equation (3) [13] [19]:

$$MK\Pi K_{m,s} = \frac{KK_{ms} + KP_{m,s} + RAV_{m,s} \cdot r + D_{m,s} + O_{m,s} + KEA_{m,s} + E\Delta_{m,s}}{Q_{\Sigma M,m,s}} \quad (3)$$

where:

- $RAV_{m,s}$: “Regulated asset base”, which is the sum of the non-depreciated value of fixed assets plus the working capital.
- r : Reasonable return on the value of the regulated asset base (defined each year by RAE).
- $D_{m,s}$: Depreciation of fixed assets.
- $O_{m,s}$: Operational expenses, namely: payroll costs, costs for maintenance and service of energy units, cost of replacement parts, insurance costs, third-parties remuneration, costs of electricity consumed by the energy units, taxes and levies.
- $KEA_{m,s}$: Expenses for renting, transferring and installing electrical generators for covering seasonal energy needs.
- $E\Delta_{m,s}$: Shared administrative costs.

Table 4. Costs and spending on mazut and diesel oil for the thermal stations of the electrical systems of the NII [18].

Year	Average mazut cost (€/tn)	Average diesel cost (€/klit)	Annual mazut cost (M€)	Annual diesel cost (M€)	Total annual oil cost (M€)	Excise duty mazut (M€)	Excise duty diesel (M€)	Total excise duty (M€)
2012	548.66	639.30	499.57	146.65	646.22	34.6	75.7	110.3
2013	491.57	599.67	413.89	130.03	543.92	31.99	71.56	103.55
2014	459.94	556.52	395.08	130.87	525.95	32.64	77.6	110.24
2015	272.67	395.60	233.43	99.48	332.91	32.53	82.99	115.52
	Total costs		1541.97	507.03	2049	131.76	307.85	439.61

The total energy production cost is, as expected, higher than the variable cost. There are cases of autonomous island systems is particularly high, mainly, due to the $KEA_{m,s}$ factor, related to seasonal needs and costs of extra electrical generators. Unfortunately, precise data regarding $KEA_{m,s}$ are not publicly available. However, fragmentary data and publications support the claim about the high values of $KEA_{m,s}$. For instance, in summer 2017, RAE approved the rental of generators with a total capacity of 37 MW for covering seasonal loads in the NII [20]. This is certainly a big value of extra electrical capacity.

In **Figure 5**, the total electricity production cost of the NII for the period 2014-2017, in descendant order, is presented. In very small islands, the total cost is particularly high. In the case of Antikithyra it reached the excessive price of 1328.03 €/MWh. Due to the low energy loads of such islands, the cost of electricity in the NII is not increased much due to the energy cost of very small islands. However, these cases are indicative of the difficulties and the high expenses for providing energy to particularly remote areas. But even in the case of Lesvos, which has the lowest total electricity production cost among the NII, the revenue of energy producers (148.967€/MWh) is almost three times higher than the revenue provided to energy producers in the interconnected energy grid of Greece. In the period 2014-2017, the weighted, average total energy cost of the NII was 186.547€/MWh. In other words, it was 3.6 times higher than the AMPIG during the same time period.

In **Table S2** of the **Appendix**, the average variable and total energy production cost per month for the systems of the NII is presented.

3.4. Statistical Correlations

The further statistical analysis of the NII energy data includes correlations between the energy production costs and other variables. This allows the verification of basic hypotheses regarding the autonomous electrical systems of the Greek islands. So, the general directions of energy planning in the NII—aiming at improving the current situation and reducing the energy costs—can be outlined, in a robust way. The statistical calculations were made with the support of SPSS software.

Data presented in Sections 3.2 and 3.3 show that there is a cost increase tendency in small autonomous systems. This is attributed to the fact that smaller electricity systems are based on energy stations, which—as a rule—use diesel oil, which is the most expensive fuel for electricity production; in 2015, the average price of diesel oil purchased by the PPC was 0.60€/lit. Moreover, the efficiency of bigger power stations is, in general, higher than the efficiency of smaller electricity generators. The correlation statistical tests verify that energy costs are related to the size of autonomous electrical systems. Specifically, both the variable and total energy production costs present:

- Strong, negative correlation with thermal plants' energy production.
- Strong, negative correlation with the installed capacity of power stations.
- Strong, negative correlation with the served population.




Figure 5. Average total energy production cost in the NII, in the period 2014-2017.

In **Table 5** the results of the correlations between these parameters are shown. As it can be seen in **Table 5**, the correlations are significant at a confidence level of 99%. The values of Spearman coefficient are high, over 0.85, at absolute values, in all cases. These findings document that small, autonomous systems are the most expensive among the NII. It would be beneficial to connect them to greater power grids. This is an actual priority of Greek energy policy, as verified by relevant official documents [21]. However, there are cases of NII which are far away from the mainland or groups of islands that have been connected to the IEG and this set obstacles to reducing energy production costs and increasing energy supply security. It is reminded that the cost variables are reduced to energy units (€/MWh) and so, the correlations presented in this Chapter are not self-evident.

Another important finding is that there is strong, negative correlation between electricity production costs and the energy produced by renewables. The energy production costs decrease when renewable energy production increases. As shown in **Table 6**, the correlations between electricity production costs and renewable energy production are significant at a confidence level of 99%. The Spearman coefficient is also high; -0.900 in the case of variable cost and -0.950 in the case of total cost. It should be noted that strong, negative correlation at a confidence level of 99% exists also between energy costs and installed capacity of renewable energy units. Hence, since diesel and mazut are relatively expensive fuels for electricity production, it is confirmed by the statistical findings that further use of renewable energy sources in the NII can lead to lower energy costs. However, as already discussed the current structure of autonomous, electrical systems sets technological restrictions to the further use of renewables. So, among else, energy storage is a possibility that should be examined thoroughly.

It is noted that Spearman coefficient is used for the correlations, because the

distribution of the variables under study is not normal and the variables are not linearly related. Furthermore, it was possible to observe that there are monotonic relations between the variables, from the available statistical data. Hence, the use of Spearman correlation can provide useful results [22].

Table 5. Correlations between cost, thermal plants’ energy production and installed capacity in the NII.

		Average annual total cost	Average annual variable cost	Served population	Thermal plants production	Installed capacity	
Spearman’s rho	Average annual total cost	Correlation Coefficient	1.000	0.938**	-0.957**	-0.956**	-0.957**
		Sig. (2-tailed)	.	0.000	0.000	0.000	0.000
		N	32	32	32	32	32
	Average annual variable cost	Correlation Coefficient	0.938**	1.000	-0.890**	-0.890**	-0.889**
		Sig. (2-tailed)	0.000	.	0.000	0.000	0.000
		N	32	32	32	32	32
	Served population	Correlation Coefficient	-0.957**	-0.890**	1.000	0.982**	0.980**
		Sig. (2-tailed)	0.000	0.000	.	0.000	0.000
		N	32	32	32	32	32
	Thermal plants production	Correlation Coefficient	-0.956**	-0.890**	0.982**	1.000	0.997**
		Sig. (2-tailed)	0.000	0.000	0.000	.	0.000
		N	32	32	32	32	32
	Installed capacity	Correlation Coefficient	-0.957**	-0.889**	0.980**	0.997**	1.000
		Sig. (2-tailed)	0.000	0.000	0.000	0.000	.
		N	32	32	32	32	32

**Correlation is significant at the 0.01 level (2-tailed).

Table 6. Correlations between cost and renewable energy production in the NII.

		Average annual total cost	Average annual variable cost	Average renewable production	
Spearman’s rho	Average annual total cost	Correlation Coefficient	1.000	0.938**	-0.950**
		Sig. (2-tailed)	.	0.000	0.000
		N	32	32	32
	Average annual variable cost	Correlation Coefficient	0.938**	1.000	-0.900**
		Sig. (2-tailed)	0.000	.	0.000
		N	32	32	32
Average renewable production	Correlation Coefficient	-0.950**	-0.900**	1.000	
	Sig. (2-tailed)	0.000	0.000	.	
	N	32	32	32	

**Correlation is significant at the 0.01 level (2-tailed).

3.5. Investigation of Improvement Options for the Autonomous System of Astypalea

Astypalea is an ideal and representative case study for investigating future perspectives of small, autonomous electrical systems in the Greek islands. It lies in the middle of the Aegean Sea (**Figure 6**), as reflected by the distance between the island and other greater islands, as well as the mainland:

- Astypalea—Kos: 55 km
- Astypalea—Naxos: 90 km
- Astypalea—Crete: 140 km
- Astypalea—Rhodes: 170 km
- Astypalea—Lavrio: 240 km
- Astypalea—Athens: 280 km

Hence, practically, the operation of an autonomous electrical system in Astypalea is compulsory, because its connection to other, greater electrical systems (or to the interconnected electricity grid of the mainland) is rather difficult.

The permanent population of the island, according to the last census, is 1334 inhabitants. The area of the island is 96.9 km². Astypalea is a rather popular tourist destination, especially for alternative summer tourism and so, its population (and consequently the energy demand) rises during the summer. In **Figure 7**, a characteristic view of the main settlement of Astypalea (Chora) is shown.

The energy system of Astypalea is based on thermal plants that use diesel oil for electricity production. The type and the power of the islands' generators are shown in **Table 7**. In 2015, the fuel consumption for electrifying the island was 2,262,347 lit of diesel oil; this is a high quantity of oil and its reduction will have positive results both from an economic and an environmental point of view. Moreover, there is an energy unit based on solar power in Astypalea that includes a photovoltaic array with peak power 320 kW. The share of solar energy in the electricity consumption ranged between 8% and 9%, in the period 2014-2017. As regards electricity consumption in Astypalea, for the period 2014-2017, the average values per month are shown in **Figure 8**. The maximum consumption (August) is almost 2.5 times higher than the minimum consumption (November). This is a typical situation for an island, whose main economic activity is summer tourism, as already discussed. The electrical load was possible to be retrieved by HEDNO, at an hourly base for the years 2014 and 2015. The hourly load is a prerequisite for conducting realistic simulations and optimizations. The peak load of the island was 2.25 MW on 08/15/2015, at 21.00. A view of the hourly load in Astypalea is given in **Figure 9**.

As far as the energy production costs are concerned, in **Figure 10**, the variable and the total cost are depicted, for the period 2014-2017, at a monthly basis. The average costs in Astypalea for the period 2014-2017 have as follows:

- Variable electricity production cost: 228.81€/MWh.
- Total electricity production cost: 379.27€/MWh.

So, Astypalea is ranked 11th among the 32 autonomous systems regarding the variable cost of electricity production and 13th regarding the total cost. It is rea-

sonable that the reduction in the island's electrification cost is utterly necessary. For improving the current situation, by considering the findings of Section 3.4, the two main choices are: 1) connecting the island to the IEG and, 2) changing the current structure of Astypalea's system and increasing the use of renewable energy sources.

Table 7. Type, fuel and capacity of the electricity generators used in the electrical system of Astypalea [23].

Type of generator	Fuel	Nominal Capacity (kW)	Power Output (kW)
STORK ABR-216S	Diesel	208	150
STORK ABR-216S	Diesel	208	150
STORK ABR-216S	Diesel	208	150
STORK ABR-216S	Diesel	208	150
MITSUBISHI S16R-PTA	Diesel	1275	1100
MITSUBISHI S16R-PTA	Diesel	1275	1100
MITSUBISHI S16R-PTA	Diesel	1275	1100



Figure 6. Map showing the position of Astypalea in Greece.



Figure 7. A view of the main settlement of Astypalea, known as Chora [24].




Figure 8. Average monthly electrical energy consumption in the energy system of Astypalea during the period 2014-2017.




Figure 9. Hourly electricity load in the autonomous system of Astypalea in the year 2015.




Figure 10. Variable and total electricity production cost per month, in the autonomous system of Astypalea, for the period 2014-2017.

3.5.1. Connecting the Autonomous System of Astypalea to the IEG

As already mentioned, although the connection to the IEG is a strategic choice of the Greek Government, Astypalea is far away from the mainland and other bigger energy systems (Rhodes, Kos, Crete, Naxos). The costs for expanding energy grids with underwater cables are quite high. By combining data from relative sources [25] [26] [27], it is estimated that the necessary cost for expanding the grid towards autonomous island systems amounts to 1,000,000€/km.

A simulation, including sensitivity analysis, was conducted with HOMER PRO x64, in order to investigate whether grid expansion towards Astypalea is a viable investment. It was proved that the expansion of the electricity grid cannot exceed 25 km, for keeping the investment financially effective. As already discussed, Astypalea is far away both from the mainland and other, bigger islands; minimum distance 55 km. Therefore, it is not feasible to expand the electricity grid just for electrifying this island.

3.5.2. Changing the Current Structure of Astypalea's Energy System

By using HOMER PRO x64, different scenarios of re-structuring the autonomous electrical system of Astypalea are analyzed. The main aim of energy optimization in the island is to reduce energy production costs in a sustainable way. Therefore, further use of renewable energy sources is necessary. The scenarios investigated are the following:

- Scenario A: Further use of renewable energy without the addition of storage
 - A1: Photovoltaics and small hydropower station.
 - A2: Photovoltaics, wind generators and small hydropower station.
- Scenario B: Further use of renewable energy with the addition of energy storage systems (Li-Ion) batteries
 - B1: Photovoltaics and battery array.
 - B2: Photovoltaics, wind generators and battery array.
 - B3: Photovoltaics, wind generators, small hydropower station and battery array.

The cases B1, B2 and B3 have been simulated with different assumptions regarding the costs of the batteries. So, there are—additionally—three cases, namely B1a, B2a, B3a which have the same structure as the abovementioned (B1, B2, B3), but are simulated with 40% lower costs of batteries, following the relevant tendency in the energy market. The assumptions regarding investment and operation and maintenance costs of the various systems are presented in **Table S3** of the **Appendix**.

Regarding energy potential, for solar and wind energy potential the data from the libraries of HOMER were used. As far as hydropower is concerned, the cause for exploiting this source of energy in an island with low rates of precipitation is the fact that there is a water reservoir near the village of Livadi. This reservoir is used for providing potable water. So, a small turbine can be used, in order to utilize the available hydraulic head when transferring water from the reservoir to consumers. According to Daniil (2018) [23], the available hydraulic head is 32 m

and, by considering the volume of the reservoir and the precipitation in the island, a small turbine with 80 kW_{el} capacity can be installed. The data retrieved by HOMER library regarding solar and wind potential, as well as the assumptions regarding hydropower in Astypalea are summarized in **Table S4** in the **Appendix**.

The simulations carried out by using HOMER PRO x64 led to the optimal solutions shown in **Table 8**, while in **Table 9** the investment costs, the unit energy cost, the annual energy cost, the annual diesel oil consumption and the renewable energy share of each scenario are presented. It is notable that in order to reduce the installed capacity of diesel generators, storage systems are necessary for avoiding power shortages. Even if the optimization results show that the renewable energy capacity and share can increase significantly without using storage systems, it is risky to operate an autonomous small system with low inertia under such conditions. The use of batteries can ensure power supply, with simultaneous increase in renewable energy use. Under favorable conditions regarding batteries' cost, the renewable energy share in Astypalea can exceed 45% and the unit energy cost can decrease by 42%, in comparison with the current situation. It should also be highlighted that the possibility to utilize hydropower, because of the existing water dam in the island, is particularly important, because of the generally higher load factors of hydro-stations, compared to PVs and wind generators. The operation of a small hydro-plan increases energy supply security and has positive impact on the system's stability.

The investment costs vary between 786,000 and 2,426,000, depending on the renewable and storage capacity installed. Such amounts are much more competitive compared to the electrification of Astypalea through submarine cables, as shown in Section 3.5.1. Of course, the present results are a first attempt to optimize Astypalea's system. Apart from a feasibility study, the further use of renewables in the island demand a precise cost-benefit analysis, based on extensive data from the energy market.

Table 8. Structure of Astypalea's energy system in the current situation and under the various future scenarios.

Scenario	Number of Diesel Generators/ Capacity (kW)	Photovoltaics (kW)	Wind Generators (kW)	Hydropower (kW)	Li-Ion Batteries (kWh)
Current situation	7/3900	320	-	-	-
A1	7/3900	1072	-	80	-
A2	7/3900	550	450	80	-
B1	7/3900	1497	-	-	500
B2	5/1700	835	700	-	500
B3	5/1700	767	650	80	400
B1a	7/3900	1135	-	-	700
B2a	5/1700	880	700	-	600
B3a	5/1700	723	675	80	500

Table 9. Investment costs, unit energy costs, annual energy costs, annual diesel oil consumption and renewable energy share for the current situation of Astypalea's energy system and under the various future scenarios.

Scenario	Investment cost (€)	Unit energy cost (€/MWh)	Annual operating cost (€)	Annual diesel oil consumption (lit)	Renewable energy share (%)
Current situation	-	230*	1,428,851*	2,262,347*	8.54*
A1	786,000	151	865,968	1,388,401	25.4
A2	1,896,000	144	735,066	1,119,778	40.6
B1	1,376,000	156	850,623	1,337,461	26.2
B2	2,546,000	143	680,213	995,450	45.0
B3	2,406,000	136	650,781	952,375	47.6
B1a	1,266,000	152	835,679	1,311,072	27.1
B2a	2,426,000	140	669,158	977,368	45.7
B3a	2,306,000	133	639,273	933,276	48.2

*Data referring to the year 2015.

4. Conclusions

The research presented in this paper highlighted: 1) the characteristics and problems related to the electrification of Greek islands not connected to the IEG, and 2) provided evidence for planning a better energy future in small, remote islands. The most important conclusions that also produce policy implications regarding sustainable development are summarized below:

- The NII of Greece demand high energy costs for their electrification (in average 2.5 times higher expenses compared to the grid of the mainland), while the present structure of the autonomous electrical systems leads to the insecurity of energy supply and does not allow the exploitation of the plentiful solar and wind energy potential of the islands.
- The use of mazut and diesel for producing more than 80% of the electrical energy needed in the NII does not only have high financial and environmental cost, but it also maintains the country's high energy dependency, mainly arising from oil imports; the energy dependency of Greece was 72.5% in 2016, while the EU average was 54% during the same period [28].
- The priority of Greece's energy planning for the future of NII with big energy loads (Crete, Rhodes, Mykonos, Paros) is the expansion of the IEG. This is a reasonable choice for cases with high energy demand and high capacities of installed RES, since the share of renewables in the country will, in general, increase in this way.
- In cases of remote islands with low energy loads, it seems that the improvement of the local autonomous systems is a better choice than the interconnection with the main electricity grid. For the case of Astypalea—peak load 2.25 MW and average load 0.72 MW—the investment for expanding the grid with submarine cables is not viable for expansion greater than 25 km.
- The case of Astypalea provides strong evidence regarding the possibility to

utilize local RES together with the use of storage systems, in order to improve current situation in small NII. The perspectives of the local autonomous system for sustainable improvement are promising: more than 45% renewable share (8.5% currently), 42% reduction in the unit energy production cost, and 58% reduction in diesel oil consumption with investment costs up to 2.4 million euros.

Apparently, the work presented in this paper presents some limitations. The main amongst them are: 1) the focus on one island, namely Astypalea, and 2) the fact that thermal energy loads are not included in the energy simulations. These limitations can be addressed by the following steps of future work:

- Collection of hourly electrical load data from all the NII of Greece and conduction of simulations like the ones presented for the case of Astypalea.
- Highlight common characteristics regarding loads, consumption and future structures of energy systems among groups of NII.
- Introduce thermal energy loads in the energy simulation, in order to gain a broad view of the energy future of small, remote islands.

In conclusion, the autonomous electrical systems of Greek islands, although currently are characterized by very high energy costs, are challenging places for implementing sustainable solutions. The NII, particularly the remote ones, are an ideal case for utilizing renewables in favor of local societies, at the basis of decentralized applications. The current model of RES development has been based on projects with great installed capacities that provide energy to the IEG, at significantly high prices. In many cases the sustainability of this RES model has been controverted. On the contrary, decentralized RES exploitation in remote islands is a mild, viable way of utilizing green energy. Government policies should more actively support this kind of energy future for NII. The present paper documents this statement, as well as pilot projects like TILOS, aiming at integrating batteries in autonomous systems [29].

Conflicts of Interest

The author declares no conflicts of interest regarding the publication of this paper.

References

- [1] Hellenic Republic (2008) Constitution of Greece. (In Greek) http://www.et.gr/images/stories/eidika_themata/a_120_2008.pdf
- [2] Katsoulakos, N. and Kaliampakos, D. (2014) What Is the Impact of Altitude on Energy Demand? A Step towards Developing Specialized Energy Policy for Mountainous Areas. *Energy Policy*, **71**, 130-138. <https://doi.org/10.1016/j.enpol.2014.04.003>
- [3] Katsoulakos, N. and Kaliampakos, D. (2016) Mountainous Areas and Decentralized Energy Planning: Insights from Greece. *Energy Policy*, **91**, 174-188. <https://doi.org/10.1016/j.enpol.2016.01.007>
- [4] Katsoulakos, N. and Kaliampakos, D. (2018) The Energy Identity of Mountainous

- Areas: The Example of Greece. *Journal of Mountain Science*, **15**, 1429-1445.
<https://doi.org/10.1007/s11629-018-4830-8>
- [5] HSA (2018) Greece in Numbers. Hellenic Statistical Authority, Piraeus.
- [6] Chatziargyriou, N. (2016) Management of Non-Interconnected Islands (NII) with High Share of Renewable Energy. (In Greek)
<https://www.deddie.gr/Documents2/PAROYSIASEIS%202016/Presentation%20Viosimes.pdf>
- [7] Prodromidis, G.N. and Coutelieris, F.A. (2011) A Comparative Feasibility Study of Stand-Alone and Grid Connected RES-Based Systems in Several Greek Islands. *Renewable Energy*, **36**, 1957-1963. <https://doi.org/10.1016/j.renene.2010.12.021>
- [8] Katsaprakakis, D. and Voumvoulakis, M. (2018) A Hybrid Power Plant towards 100% Energy Autonomy for the Island of Sifnos, Greece. Perspectives Created from Energy Cooperatives. *Energy*, **161**, 680-698.
<https://doi.org/10.1016/j.energy.2018.07.198>
- [9] Zafeiratou, E. and Spataru, C. (2018) Sustainable Island Power System—Scenario Analysis for Crete under the Energy Trilemma Index. *Sustainable Cities and Society*, **41**, 378-391. <https://doi.org/10.1016/j.scs.2018.05.054>
- [10] Walker, M. (2016) HOMER Optimizer, a Faster Path to Finding Least-Cost Microgrid Options.
<http://microgridnews.com/homer-optimizer-a-faster-path-to-finding-least-cost-microgrid-options>
- [11] HSA (2012) Hellenic Statistical Authority. Demographic Characteristics 2011. (In Greek) <http://www.statistics.gr/el/statistics/-/publication/SAM03>
- [12] HDNO (2018) Informative Bulletin Regarding Electricity Production in the Non-Interconnected Islands for April 2018. Hellenic Electricity Distribution Network Operator, Athens. (In Greek)
- [13] RAE (2014) Regulatory Authority for Energy. Non-Interconnected Islands. (In Greek) http://www.rae.gr/site/categories_new/electricity/market/mdn.csp
- [14] OEM (2018) Monthly Bulletin of Daily Energy Planning. Operator of Electricity Market, Athens. (In Greek)
- [15] IPTO (2018) Independent Power Transmission Operator. (In Greek)
<http://www.admie.gr/leitoyrgia-dedomena/leitoyrgia-agoras-ilektrikis-energeias/prothesmiaki-agera-dedomena-eisodoy/problepsi-fortioy>
- [16] Government Gazette (2012) Law 4027/2012. Hellenic Republic, Athens. (In Greek)
- [17] HDNO (2015) Methodology for Calculating Collaterals for Load Representatives during the Transitional Period of the Implementation of the Non-Interconnected Islands Regulation. Hellenic Electricity Distribution Network Operator, Athens. (In Greek)
- [18] Kounalakis, M. and Kollias, F. (2018) Energy Press, Portal for Energy.
<https://energypress.gr/news/mystirio-me-ta-ekaton-tades-ekatommyria-eyro-gia-ta-yko-tis-dei>
- [19] RAE (2018) Regulation for Operating the Electrical Systems of Non-Interconnected Islands (NII Regulation). 2nd Edition, Regulatory Authority for Energy, Athens. (In Greek)
- [20] Energypress (2017) Energypress, Portal for Energy. (In Greek)
<https://energypress.gr/news/egkrithike-i-egkatastasi-prostheticis-ishyos-sta-nisia-gia-kalokairi-i-rae-vazei-telos-sti>
- [21] Government Gazette (2018) Approval of the Ten-Year Development Plan of the

- National System of Electrical Energy Transmission. Hellenic Republic, Athens. (In Greek)
- [22] Zafeiropoulos, K. (2008) Open Digital Classes, Statistical Analysis Using a Computer. University of Macedonia, Thessaloniki.
<http://opencourses.uom.gr/assets/site/public/127/70-Statistikh-Analysi-08-Zafeiropoulos.pdf>
- [23] Daniil, V. (2018) Investigation of Renewable Energy Use in the Non-Interconnected Island of Astypalea. Diploma Thesis, National Technical University of Athens, Athens. (In Greek)
- [24] Aegean Sea Villas (2017) Aegean Sea Villas—Luxury Seaside Detached Homes. (In Greek) <https://aegeanseavillas.com/el/astypalaia-gr/astypalaia-gr>
- [25] Papadopoulos, M., Papanthasiou, S. and Karamanou, E. (2008) Update of the Strategic Study Regarding the Connection of Islands to the Interconnected Electricity Grid. Research Project, Regulatory Authority for Energy, Athens. (In Greek)
- [26] RAE (2011) Development Study of Crete’s Electric System. Technical Report, Executive Summary, Regulatory Authority for Energy, Athens. (In Greek)
- [27] Frangkoulis, E. (2016) Electrical Connection of Crete with the Mainland System. Postgraduate Thesis, University of Pireus, Pireus. (In Greek)
- [28] Energia.gr (2018) National Strategy and Petroleum. (In Greek)
<https://www.energia.gr/article/147553/ethnikh-strathgikh-kai-petrelaio>
- [29] Tilos (2018) Technology Innovation for the Local Scale. Optimum Integration of Battery Energy Storage. Website of Research Project.
<https://www.tiloshorizon.eu>

Appendix

Table S1. Average monthly energy consumption in the electrical systems of the non-interconnected islands in MWh.

		Agios Efstratios	Agathonissi	Amorgos	Anafi	Antikyhtira	Arkioi	Astypalea	Gavdos	Dosnoussa	Erikoussa	Thira	Ikaria	Karpathos	Crete
JAN	Thermal	0.00	0.00	23.26	0.00	0.00	0.00	31.87	0.00	0.00	0.00	56.01	234.14	299.68	48,823.23
	RES	101.43	68.44	678.53	84.18	21.96	19.99	492.61	37.68	48.46	48.78	8127.05	2244.55	2419.13	190,154.40
FEB	Thermal	0.00	0.00	26.27	0.00	0.00	0.00	34.43	0.00	0.00	0.00	57.86	234.36	304.29	45,028.67
	RES	86.81	57.00	603.09	76.80	20.14	19.15	421.73	35.11	44.36	55.70	7479.09	1858.88	1933.57	159,175.29
MAR	Thermal	0.00	0.00	39.33	0.00	0.00	0.00	44.14	0.00	0.00	0.00	77.30	237.15	388.73	51,792.66
	RES	91.10	60.16	619.25	76.19	20.68	18.09	414.17	38.01	45.69	51.74	8686.64	1924.53	1928.12	157,425.51
APR	Thermal	0.00	0.00	45.96	0.00	0.00	0.00	54.25	0.00	0.00	0.00	95.39	234.32	352.30	46,113.36
	RES	78.24	51.21	628.37	71.51	19.44	20.03	381.90	33.42	43.77	55.56	10,704.09	1686.99	1798.37	155,798.54
MAY	Thermal	0.00	0.00	51.83	0.00	0.00	0.00	59.04	0.00	0.00	0.00	105.57	237.98	396.93	50,692.49
	RES	77.82	52.64	654.66	82.48	19.87	28.87	411.11	35.97	54.45	56.25	14,135.82	1627.99	2411.24	183,165.08
JUN	Thermal	0.00	0.00	51.34	0.00	0.00	0.00	60.26	0.00	0.00	0.00	109.09	232.85	434.49	54,936.32
	RES	86.19	55.27	833.12	114.00	20.23	36.64	533.90	42.87	86.87	66.44	17,273.43	1890.34	3349.81	216,448.59
JUL	Thermal	0.00	0.00	56.13	0.00	0.00	0.00	66.02	0.00	0.00	0.00	113.06	347.09	535.56	83,101.92
	RES	111.35	74.77	1217.40	171.85	24.10	47.19	798.20	51.66	131.32	107.18	21,022.93	2520.74	4349.55	241,549.41
AUG	Thermal	0.00	0.00	49.14	0.00	0.00	0.00	61.25	0.00	0.00	0.00	105.93	318.24	475.67	77,410.77
	RES	130.24	74.85	1449.93	229.84	28.19	56.88	986.81	55.46	154.16	134.01	22,508.50	3196.82	4998.12	256,233.51
SEP	Thermal	0.00	0.00	45.93	0.00	0.00	0.00	57.67	0.00	0.00	0.00	96.26	254.69	395.79	54,037.38
	RES	84.10	54.71	955.92	128.52	23.60	39.99	580.78	45.98	95.79	71.33	18,537.99	2130.79	3686.15	228,557.63
OCT	Thermal	0.00	0.00	45.44	0.00	0.00	0.00	54.59	0.00	0.00	0.00	83.25	285.96	383.56	55,233.22
	RES	78.26	47.69	639.66	78.17	19.94	27.76	408.75	37.32	52.33	54.40	13,501.54	1723.73	2120.14	181,347.86
NOV	Thermal	0.00	0.00	31.17	0.00	0.00	0.00	38.28	0.00	0.00	0.00	66.40	237.03	300.00	47,211.07
	RES	84.32	48.64	593.91	72.43	19.07	19.07	385.06	33.74	43.01	49.77	7941.67	1848.86	1773.05	149,922.77
DEC	Thermal	0.00	0.00	24.16	0.00	0.00	0.00	27.71	0.00	0.00	0.00	53.64	266.65	316.25	53,480.38
	RES	95.74	60.78	650.85	78.03	21.27	18.86	446.12	36.75	46.03	49.16	8091.01	2138.77	2150.86	180,133.07

		Kythnos	Kos- Kalymnos	Lesvos	Lemnos	Megisti	Milos	Mykonos	Othoni	Paros	Patmos	Rhodes	Samos	Serifos	Sifnos
JAN	Thermal	21.20	3698.20	3796.77	534.86	0.00	606.91	360.16	0.00	2951.49	199.06	8570.98	2004.49	11.52	28.47
	RES	645.40	21,259.13	25,480.72	4835.49	251.16	3154.17	6195.70	46.12	11,808.04	1262.40	46,689.46	10,425.91	597.42	1166.16
FEB	Thermal	22.66	3184.70	4199.54	572.55	0.00	633.17	344.13	0.00	2669.22	162.21	7496.10	1892.15	11.66	32.02
	RES	559.77	17,506.30	20,313.58	4063.95	219.92	2896.26	5652.36	41.44	10,306.99	1051.00	37,745.82	9092.72	539.48	1018.34
MAR	Thermal	28.35	3325.68	4199.28	617.63	0.00	696.64	392.56	0.00	3303.06	157.89	8566.97	1954.47	16.36	44.01
	RES	584.67	16,801.38	19,952.70	4163.62	214.88	2957.55	6307.41	41.04	10,315.43	1071.94	35,744.38	8918.58	545.32	1038.38
APR	Thermal	38.18	3257.96	3816.95	552.40	0.00	484.64	333.54	0.00	2679.51	126.94	8296.98	1616.26	18.00	53.06
	RES	1276.46	16,715.28	16,896.26	3624.04	199.41	5924.85	7851.31	44.23	11,184.83	1074.06	36,875.27	7362.95	1414.29	2235.96

Continued

MAY	Thermal	37.95	3747.12	3951.06	611.09	0.00	575.83	329.21	0.00	2728.85	125.57	9995.05	1895.75	20.26	61.41
	RES	559.38	26,476.75	16,734.59	3524.21	215.34	3290.20	11,385.73	45.04	12,847.41	1121.45	54,268.93	7870.36	530.10	1232.66
JUN	Thermal	40.60	4402.01	3535.01	570.35	0.00	545.42	360.29	0.00	3049.14	189.73	13,577.41	2336.83	23.36	62.85
	RES	700.47	34,907.44	19,608.96	4221.53	279.11	3782.49	14,862.04	54.40	17,800.85	1363.85	69,761.05	9212.87	731.05	1688.14
JUL	Thermal	41.64	5784.85	5033.14	815.86	0.00	1034.85	513.70	0.00	5036.93	381.52	16,685.49	3581.75	25.97	67.63
	RES	1069.45	43,159.25	23,193.75	5380.37	430.96	4484.24	19,103.93	77.69	23,794.45	1699.23	90,348.54	10,560.23	1124.19	2441.26
AUG	Thermal	39.85	5001.38	4799.17	943.15	0.00	946.27	508.37	0.00	4880.00	335.01	15,994.22	3563.68	24.00	64.44
	RES	1380.61	47,360.10	25,553.53	5940.79	478.29	4916.28	20,956.38	103.66	27,955.77	2158.92	97,148.20	12,114.94	1407.29	2884.18
SEP	Thermal	40.64	4252.53	3762.27	708.66	0.00	565.80	341.14	0.00	3308.94	209.71	13,260.05	2480.87	20.83	56.26
	RES	739.56	36,598.14	19,384.48	4201.32	365.91	3844.59	16,525.09	54.25	18,138.47	1441.40	77,250.53	9657.49	736.86	1755.40
OCT	Thermal	34.21	4373.31	3612.57	607.83	0.00	688.18	411.57	0.00	3471.26	172.41	11,003.16	2346.28	17.91	51.21
	RES	519.63	24,780.65	16,770.67	3635.77	241.87	2703.10	9079.16	41.58	10,795.34	1006.96	54,775.86	7222.32	457.45	1046.06
NOV	Thermal	25.30	2896.86	3046.98	481.27	0.00	579.08	312.82	0.00	2833.77	124.70	6415.24	1907.26	14.65	38.14
	RES	506.43	15,606.44	19,487.31	3965.84	201.72	2831.93	5578.17	38.65	9901.65	947.88	33,335.75	8014.29	446.47	963.68
DEC	Thermal	19.80	3846.98	4085.12	581.95	0.00	622.54	375.76	0.00	3241.56	197.68	7914.10	2371.81	11.90	30.61
	RES	599.34	19,228.52	23,794.03	4550.83	244.03	2848.85	5835.81	40.03	11,080.45	1142.23	41,231.24	9693.37	514.71	1112.25

		Skyros	Symi	Syros	Chios
JAN	Thermal	19.29	10.65	504.06	2142.63
	RES	1304.54	1152.83	8364.84	18,530.23
FEB	Thermal	26.07	15.57	511.30	2205.43
	RES	1197.90	962.52	7019.94	15,049.81
MAR	Thermal	37.45	21.81	620.71	2338.10
	RES	1223.11	937.74	7025.67	14,918.21
APR	Thermal	51.82	28.78	508.42	2076.59
	RES	1049.31	897.79	6335.57	11,790.12
MAY	Thermal	59.33	30.49	472.41	2301.05
	RES	1021.19	993.60	6260.66	11,545.10
JUN	Thermal	54.24	31.20	536.61	2133.50
	RES	1220.58	1261.80	7195.06	13,639.65
JUL	Thermal	59.98	31.76	860.41	3104.68
	RES	1723.26	1634.98	8733.79	16,577.99
AUG	Thermal	59.95	29.28	852.97	2844.79
	RES	2028.79	2015.93	9825.53	19,195.02
SEP	Thermal	46.79	24.90	593.92	2169.00
	RES	1198.98	1429.76	7257.50	13,755.63
OCT	Thermal	37.06	21.22	691.24	2269.77
	RES	993.04	1081.96	6225.10	11,966.58
NOV	Thermal	26.85	14.86	600.81	2062.42
	RES	1065.20	883.34	6391.76	13,842.28
DEC	Thermal	21.78	11.24	587.92	2395.38
	RES	1228.43	1029.99	7612.93	17,481.04

Table S2. Average monthly variable and total electricity production costs in the electrical systems of the non-interconnected islands in €/MWh.

		Agios Efstراتيجιος	Agathonissi	Amorgos	Anafi	Antikyhtira	Arkioi	Astypalea	Gavdos	Dosnoussa	Erikoussa	Thira	Ikaria	Karpathos	Crete
JAN	Variable	267.09	326.94	230.04	266.64	391.27	398.90	223.84	278.28	302.90	319.97	123.40	216.30	126.22	138.66
	Total	450.81	593.11	389.87	567.34	1224.55	921.28	358.92	566.45	1073.58	835.24	211.23	359.40	247.92	180.50
FEB	Variable	271.38	316.08	224.47	294.46	386.13	401.14	227.29	277.68	318.19	321.94	133.26	195.67	130.34	142.87
	Total	433.95	718.97	386.80	1027.30	1280.73	1134.27	384.30	649.66	1055.26	765.57	262.47	351.10	281.53	194.12
MAR	Variable	275.29	329.88	226.76	258.33	391.77	609.87	233.08	282.41	315.94	324.74	139.95	210.24	117.47	139.65
	Total	732.81	637.34	395.14	523.08	1216.64	1537.58	382.47	563.49	1281.23	848.92	229.95	369.72	258.26	190.94
APR	Variable	270.32	726.25	226.41	273.64	371.38	368.24	224.64	297.69	320.58	337.68	123.16	200.18	112.29	133.51
	Total	481.27	1855.48	424.64	670.16	1354.44	1023.87	409.43	717.74	1371.80	830.71	210.85	394.93	336.01	190.04
MAY	Variable	270.58	333.30	224.78	269.42	427.50	307.46	233.95	282.01	321.96	332.97	134.24	227.19	111.63	134.26
	Total	538.82	1006.39	424.10	772.32	1510.40	728.47	403.56	714.67	1248.32	837.32	195.51	416.67	259.51	186.19
JUN	Variable	260.64	321.89	226.94	255.39	392.43	303.33	226.25	262.95	264.66	297.31	144.12	228.09	116.75	143.14
	Total	497.31	905.21	370.35	472.62	1452.95	634.68	360.61	581.66	808.42	801.54	210.22	411.98	237.42	192.00
JUL	Variable	248.50	309.36	225.48	241.46	363.81	286.59	227.82	286.54	261.06	294.73	158.41	229.77	104.20	146.27
	Total	478.78	1238.33	334.89	358.79	1196.73	592.86	357.90	705.40	605.95	594.81	206.08	361.24	181.17	183.89
AUG	Variable	253.07	294.95	218.03	243.57	359.86	303.43	221.10	306.53	248.82	257.32	142.99	215.57	104.94	145.66
	Total	549.02	893.97	274.79	378.79	1083.91	517.70	309.67	609.19	573.91	442.28	182.13	317.84	166.32	176.27
SEP	Variable	255.21	312.77	218.11	235.24	362.96	299.04	222.73	307.37	243.29	297.77	128.49	217.34	106.65	145.52
	Total	718.07	986.20	335.02	550.37	1202.45	795.58	324.44	777.04	761.79	701.59	179.53	355.56	189.09	180.45
OCT	Variable	261.98	290.31	217.44	293.27	406.23	323.49	229.76	296.05	295.13	327.96	100.73	222.98	112.42	132.22
	Total	511.27	1053.40	401.88	811.55	1532.87	729.35	395.71	710.77	1360.84	983.25	162.46	413.82	241.46	163.44
NOV	Variable	250.69	314.22	214.49	270.89	397.48	427.54	253.10	294.87	293.85	311.79	101.78	212.88	102.74	133.77
	Total	524.03	897.81	400.46	582.70	1417.60	1068.78	471.98	642.49	1152.87	884.28	217.51	379.49	274.74	188.53
DEC	Variable	253.45	271.69	217.66	268.55	355.55	381.50	222.13	283.47	312.68	285.75	103.06	218.97	103.16	132.37
	Total	490.59	718.38	424.10	803.38	1463.11	1178.03	392.27	728.10	1268.85	894.64	200.13	363.57	246.28	180.11

		Kythnos	Kos-Kalymnos	Lesvos	Lemnos	Megisti	Milos	Mykonos	Othoni	Paros	Patmos	Rhodes	Samos	Serifos	Sifnos
JAN	Variable	228.99	95.45	116.59	112.48	273.69	101.87	225.30	341.90	101.54	231.33	125.42	105.78	230.57	227.11
	Total	392.23	153.67	151.40	182.54	448.91	210.08	334.27	726.03	153.62	313.33	185.75	168.78	376.75	364.94
FEB	Variable	231.19	98.74	114.15	113.30	280.43	103.00	232.46	301.94	104.14	230.05	143.37	107.18	224.59	230.16
	Total	402.20	175.22	153.93	194.04	507.56	227.98	355.52	749.54	179.96	331.56	219.53	182.64	378.64	395.97
MAR	Variable	234.63	104.88	103.19	108.75	274.89	98.00	225.91	358.29	100.95	216.89	128.28	99.42	222.66	217.13
	Total	399.33	182.47	158.55	186.08	511.06	214.00	343.03	848.14	159.87	310.43	203.81	173.57	373.39	376.30
APR	Variable	185.26	95.06	94.69	114.64	250.07	83.17	228.59	325.54	97.05	217.98	121.42	100.12	177.96	176.22
	Total	310.87	173.35	148.21	221.81	575.21	189.68	329.62	906.14	156.79	329.96	203.79	187.98	312.93	301.79
MAY	Variable	225.42	88.72	98.86	107.92	263.60	94.78	222.86	339.69	95.01	221.05	125.55	96.56	230.23	223.93
	Total	435.64	139.50	165.09	217.28	487.96	200.88	304.11	742.54	160.92	325.41	190.62	188.03	405.51	361.94

Continued

JUN	Variable	222.43	91.19	99.96	105.68	264.48	92.25	230.01	345.31	95.44	233.14	132.73	96.37	226.26	224.92
	Total	402.39	137.18	171.27	206.85	496.65	193.54	298.25	846.16	142.04	347.02	180.71	185.92	400.94	349.63
JUL	Variable	222.03	92.86	100.24	103.50	257.85	90.80	231.11	311.15	103.74	216.78	139.21	90.19	221.85	224.56
	Total	387.02	124.86	147.29	181.10	391.87	168.63	277.33	604.71	135.13	288.68	173.92	154.53	308.21	302.85
AUG	Variable	221.12	99.83	95.75	101.50	269.06	89.82	227.56	287.98	102.85	218.24	154.33	94.33	221.05	218.97
	Total	306.53	125.68	129.03	157.38	356.82	152.16	260.88	459.08	128.06	264.64	186.41	150.85	307.02	276.28
SEP	Variable	225.29	95.92	92.90	105.97	242.32	92.67	221.85	322.93	97.91	215.62	135.04	95.97	222.11	217.68
	Total	399.65	129.53	141.07	191.12	376.61	175.27	266.83	674.17	141.36	289.12	167.50	168.48	359.83	314.67
OCT	Variable	226.62	87.44	95.34	103.07	254.10	92.97	220.24	401.41	93.88	218.35	112.77	97.82	230.01	223.30
	Total	429.79	131.91	137.59	182.44	546.70	195.04	289.02	979.01	147.28	317.43	152.78	195.33	408.44	417.81
NOV	Variable	220.53	88.41	98.57	103.79	270.10	93.32	215.98	397.13	90.02	215.55	105.86	93.22	221.34	219.44
	Total	437.16	169.71	146.82	210.77	536.69	203.72	343.85	932.10	175.03	334.26	191.52	180.08	429.08	391.05
DEC	Variable	228.76	88.82	99.09	103.04	220.74	92.32	221.80	356.86	89.60	212.46	101.36	89.34	211.62	216.70
	Total	504.87	156.71	137.36	194.76	458.00	215.42	327.03	933.90	156.89	308.30	168.56	162.15	469.13	407.61

		Skyros	Symi	Syros	Chios
JAN	Variable	216.27	232.24	105.35	95.94
	Total	332.52	329.78	172.84	140.73
FEB	Variable	226.58	229.87	109.37	99.28
	Total	362.32	360.90	193.33	155.39
MAR	Variable	224.87	219.87	105.13	96.09
	Total	359.50	309.89	190.17	152.86
APR	Variable	230.93	231.52	102.07	96.37
	Total	385.30	405.80	206.61	174.81
MAY	Variable	227.98	227.13	104.54	96.38
	Total	392.61	351.23	206.54	177.07
JUN	Variable	222.72	227.36	104.30	91.62
	Total	389.48	352.14	203.08	166.48
JUL	Variable	222.41	250.63	104.40	89.04
	Total	313.96	384.24	183.57	147.62
AUG	Variable	215.98	219.17	98.65	88.44
	Total	286.41	275.27	166.02	132.85
SEP	Variable	213.75	215.89	101.59	89.88
	Total	346.83	337.18	189.13	151.59
OCT	Variable	222.73	229.73	103.07	91.56
	Total	447.33	368.01	190.65	156.17
NOV	Variable	218.44	218.36	98.11	89.46
	Total	362.79	368.53	193.12	151.44
DEC	Variable	213.54	214.95	98.45	85.16
	Total	342.34	346.81	183.72	134.26

Table S3. Investment, operation and maintenance costs used in the energy simulations.

Type of technology	Investment cost	Replacement cost	Operation and maintenance cost	Fuel cost
Photovoltaic panels	700€/kW	550€/kW	21€/kW/year	-
Wind generators (nominal power 25 kW)	61,250€/pc	55,000€/pc	1225€/pc/year	-
Small Hydro Turbine (nominal power 80 kW)	108,000€/pc	90,000€/pc	4320€/pc/year	-
Batteries Li-Ion (capacity 100 kWh)	70,000€/pc	30,000€/pc	1000€/ pc/year	-
Batteries Li-Ion (capacity 100 kWh) <u>Low cost scenario</u>	30,000€/pc	10,000€/pc	1000€/pc/year	-
Converter DC/AC	250€/kW	230€/kW	-	-
Diesel electro generator	-*	1200€/kW	0.05€/oper. h	0.60€/lit diesel

*The investment cost of diesel generators has been neglected, since there are already installed in the island. So, only replacement costs have been considered.

Table S4. Renewable energy potential in Astypalea.

Month	Clearance Index*	Daily Radiation (kWh/m ² /day)*	Average Wind Speed (m/sec)*	Volumetric Water flow (lit/sec)**
JAN	0.497	2.400	6.910	300
FEB	0.529	3.270	7.580	300
MAR	0.578	4.650	6.530	300
APR	0.619	6.100	5.740	200
MAY	0.670	7.420	5.080	200
JUN	0.721	8.340	5.160	150
JUL	0.739	8.350	6.240	150
AUG	0.731	7.520	5.760	150
SEP	0.711	6.150	5.360	100
OCT	0.649	4.360	5.700	200
NOV	0.547	2.800	6.170	300
DEC	0.467	2.060	6.630	300

*Based on HOMER libraries that follow NASA meteorology and solar energy database, **Based on assumptions from data retrieved by Daniil (2018).